

产品认证证书

II型自愿认证

证书编号: CQC2017010307957682

发证日期: 2020年05月29日

有效期至: 2031年05月20日

委托人名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
制造商名称	浙江天正电气股份有限公司
及注册地址	浙江省乐清市柳市镇苏吕工业区
生产企业名称	浙江天正电气股份有限公司
及生产地址	浙江省乐清市经济开发区中心大道 288 号
产品名称和系列、 规格、型号	塑料外壳式断路器 TGM3E-1250M,TGM3E-1250H;
产品标准和技术要求	GB 14048.2-2008
认证模式	产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 (www.cnca.gov.cn) 查验证书信息



授权签字人

签发

陈昕 陆楠

中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0057257

CERTIFICATE OF PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2017010307957682

Valid from: May.29,2020

Valid until: May.20,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Zhejiang Tengen Electrics Co.,Ltd.
Sulv Industry Zone,Liushi,Yueqing,Zhejiang,P.R.China

NAME AND LOCATION OF THE FACTORY Zhejiang Tengen Electrics Co.,Ltd.
No.288 Central Avenue, Development Zone, Yueqing City, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION Molded case circuit breaker
TGM3E-1250M,TGM3E-1250H;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB 14048.2-2008

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGN BY

陈昕

SIGNATURE

陆楠



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0057257

产品认证证书

II型自愿认证

附 录

证书编号: CQC2017010307957682

第 1 页 共 4 页

纸 号: 57257

TGM3E-1250M, TGM3E-1250H

Ui: 1000V;

Uimp: 8kV;

Ue: AC380/400/415V, AC660/690V;

In: 1250A(500A~1250A 可调);

过电流脱扣器类型: 电子式;

AC380/400/415V: Ics=50kA(M 型), Icu=50kA(M 型), Icw=15kA/1s(M 型);

Ics=50kA(H 型), Icu=80kA(H 型), Icw=15kA/1s(H 型);

AC660/690V: Ics=20kA(M 型), Icu=20kA(M 型);

Ics=20kA(H 型), Icu=30kA(H 型);

使用类别: B;

频率: 50/60Hz;

适用于隔离;

极数: 3P;

配用的辅助触头 OF-M、报警触头 SD-M (1NO1NC, 2NO2NC, 4NO4NC);

Ith: 6A;

AC-15: Ue/Ie: AC380/400/415V/1A;

DC-13: Ue/Ie: DC110/220/250V/0.15A;

符合附录 N 的电子附件:

电动操作机构 CD2: AC220/230V(50/60Hz), AC380/400V(50/60Hz);

欠压脱扣器 QT: AC220/230V(50/60Hz), AC380/400V(50/60Hz);

电子分励报警附件: AC220V(50Hz), DC24V;

型号解释:

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2017010307957682

第 2 页 共 4 页

纸 号: 57257

TG M 3 E - 1250 □ □ / □ □ □ □ □ □

过载报警不跳闸代号 (见注 7)
用途代号 (见注 6)
附件代号 (见注 5)
脱扣方式代号 (见注 4)
极数代号 (见注 3)
操作方式代号 (见注 2)
短路分断能力级别 (见注 1)
壳架等级额定电流(A)
电子式
设计序号
塑料外壳式断路器
企业特征代号

短路分断能力级别 (注 1)	型号解释	代号	操作方式 代号 (注 2)	型号解释	代号
	较高分断型	M		手柄直接操作	无
	高分断型	H		电动操作	P

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2017010307957682

第 3 页 共 4 页

纸 号: 57257

极数代号 (注3)	型号解释	代号	脱扣方式 代号(注4)	型号解释	代号
	三极	3		电子式	3

附件代号 (注5)	附件种类		代号
	无		00
	报警触头		08
	分励脱扣器		10
	辅助触头		2
	欠电压脱扣		30
	分励脱扣器、辅助触头		40
	欠电压脱扣器、分励脱扣器		50
	二组辅助触头		60
	欠电压脱扣器、辅助触头		70
	分励脱扣器、报警触头		18
	辅助触头、报警触头		28
	欠电压脱扣器、报警触头		38
	分励脱扣器、辅助触头、报警触头		48
	辅报触头		58
	二组辅助触头、报警触头		68
	欠电压脱扣器、辅助触头、报警触头		78

注: 此附录与证书同时使用时有效。



中国质量认证中心



产品认证证书

II型自愿认证

附 录

证书编号: CQC2017010307957682

第 4 页 共 4 页

纸 号: 57257

用途代号 (注 6)	型号解释	代号	过载报警 不跳闸代 号(注 7)	型号解释	代号
	配电用保护	无		无报警可调	无
	电动机保护	2		有报警可调	III

注: 此附录与证书同时使用时有效。



中国质量认证中心

